

WELL 2 MAINTENANCE PROJECT 2024
Wasco Sanitary District
ADDENDUM NO. 2
March 6, 2024

This addendum applies to Contract Documents and Project Specifications entitled: "Well 2 Maintenance Project" Dated February 15, 2024

This Addendum forms part of the Contract Documents and Plans and modifies the original bidding documents as noted below. Acknowledge receipt of this Addendum on the Bid Form. Bids shall include all items included in this Addendum. This Addendum shall be stapled to the original Contract Documents which shall be included as part of the "SEALED BID DOCUMENTS."

Contract Documents

The following revisions/clarifications shall be made part of the Contract Documents, and shall be considered in preparing the proposal:

1. See included revised Bid Form from pages 9-11. Page 9 item 8 is revised to match original specification quantity of 1 and note below bid table added. Page 10 items 2,3 and 4 are revised to match the original specification quantity of 1 and a note below the bid table added.
2. Any exceptions and qualifications to bid pricing should be clearly noted on the bid form or on an attached document with reference on the bid form.
3. Any vegetation removal in the area of well head will be the responsibility of the contractor. The contractor shall remove only what is necessary to complete the project safely. Replacement will not be the responsibility of the contractor.

BID FORM – SCHEDULE OF PAY ITEMS

	<u>BASIC SERVICE ITEMS</u>	<u>QNTY</u>	<u>UNIT</u>	<u>UNIT PRICE</u>		<u>AMOUNT</u>
1.	Mobilization	1	L.SUM			
2.	Televised Well Survey with DVD report	1	L.SUM			
3.	Removal of Pump and Motor and verification of static water level	1	L.SUM			
4.	Disassembly of pump bowl, inspection and micrometer check and written report	1	L.SUM			
5.	Inspection and service of Byron Jackson Motor, oil, gasket and filter replacement	1	L.SUM			
6.	Hypot Test Submersible Cable with written report	660	L. FEET			
6.	Sandblast 6 inch column pipe (inside and outside) for inspection and reuse. (includes transportation and grit)	660	L. FEET			
7.	Epoxy coating of 6 inch column pipe (inside and outside) compliant with NSF & AWWA	660	L. FEET			
8.*	Rethread ends of column piping	1	EACH			
9.	Rebuild Bowl Assembly with new wear rings, bushings, stainless steel shaft, stainless steel collets and bearings and reassemble. Bowl Assembly to be painted to manufacturers specifications.	1	LSUM			
10.	Reinstall Pump and Motor, 2 hour performance test	1	L.SUM			
11.	Demobilize and clean up	1	LSUM			
				SUB TOTAL		

* Item 8 is for unit pricing purposes. Actual costs will be based on this unit price and the quantity of each item replaced.

	REPLACEMENT ITEMS	QNTY	UNIT	UNIT PRICE		AMOUNT
1.	Replacement ¼ "plastic air line rated for 1000 psi	660	L. FEET			
2.*	Replacement 6 inch Schedule 40 T & C single random length line pipe – epoxy coated steel, with stainless steel set screws	20	L. FEET			
3.*	Couplings – 6"	1	EACH			
4.*	6" surge control valve	1	EACH			
				SUB TOTAL		

* Items 2,3 & 4 are for unit pricing purposes. Actual costs will be based on this unit price and the quantity of each item replaced.

	<u>ADDITIONAL ITEMS AS ORDERED</u>	<u>QNTY</u>	<u>UNIT</u>	<u>UNIT PRICE</u>		<u>AMOUNT</u>
1.	Additional Test Pumping	1	HOUR			
2.	Bailing Well	1	HOUR			
3.	Power Cable Replacement (600V - #4/0 w/grnd.)	660	FEET			
4.	Shipping Cost for motor to qualified motor repair shop Name / Destination _____	1	L.SUM			
5.	Motor Dis-assembly and inspection at qualified motor repair facility	1	L.SUM			
6.	New Replacement Motor Manufacturer _____ Estimated Days to Delivery _____	1	EACH			
7.	Rebuilt Replacement Motor Manufacturer _____ Estimated Days to Delivery _____	1	EACH			
8.	Rebuild Existing Motor Convert to Mechanical seal with motor rewind Estimated Days to Delivery _____	1	EACH			
9.	New Replacement Pump Manufacturer _____ Estimated Days to Delivery _____	1	EACH			
10.	Decommissioning of Existing Byron Jackson Type H Motor without purchase of a replacement Byron Jackson or Sun Star Motor	1	EACH			
11.	Decommissioning of Existing Byron Jackson Type H Motor with purchase of a replacement Byron Jackson or Sun Star Motor. Only required if price is less than item 10.	1	EACH			